Comments 45

SM 0164-07 Cape St. Mary's Marina
Concept 07-13200005

Approval

51829-6764

Martin O'Malley
Governor

Anthony G. Brown
Lt. Governor



Margaret G. McHale Chair

Ren Serey
Executive Director

STATE OF MARYLAND CRITICAL AREA COMMISSION CHESAPEAKE AND ATLANTIC COASTAL BAYS

1804 West Street, Suite 100, Annapolis, Maryland 21401 (410) 260-3460 Fax: (410) 974-5338 www.dnr.state.md.us/criticalarea/

December 5, 2008

Ms. Susan McCauley
St. Mary's County Government
Department of Land Use and Growth Management
P O Box 653
Leonardtown, Maryland 20650

Re: Cape St. Mary's Marina – Major Site Plan

Dear Ms. McCauley:

We received a revised site plan for review and comment on November 26, 2008 from the applicant. The applicant is proposing to re-develop an existing marina facility. The entire site is within the expanded Critical Area Buffer. The restaurant will be relocated but will not exceed the footprint area of the existing restaurant. The boat shop will be reconstructed within the same footprint as the existing shop building. Because the site of the existing restaurant is to be used for parking and access improvements, it is not available for plantings. Therefore, an area equivalent to the footprint of the restaurant will be established on site in the Buffer with forest vegetation. A boardwalk for access to the boat slips will be provided, and planting beds will be installed as required under by the County. This office has no additional comments regarding the proposal.

Thank you for the opportunity to provide comments. If you have any questions, please contact me at 410-260-3475.

Sincerely,

Marshall Johnson

Natural Resource Planner

SM 157-03 164-07



STATE OF MARYLAND CRITICAL AREA COMMISSION CHESAPEAKE AND ATLANTIC COASTAL BAYS

1804 West Street, Suite 100, Annapolis, Maryland 21401 (410) 260-3460 Fax: (410) 974-5338 www.dnr.state.md.us/eriticalarea/

April 13, 2007

Ms. Susan McCauley
St. Mary's County Government
Department of Land Use and Growth Management
P O Box 653
Leonardtown, Maryland 20650

Re: Cape St. Mary's Marina

Dear Ms. McCauley:

Thank you for submitting the above referenced site plan for review and comment. The applicant is proposing to redevelop an existing marina. The site is 37 acres in size, designated as Limited Development Area and designated as a water-dependent facility. The applicant is seeking to redevelop the marina, including removing an existing restaurant/marina office and constructing a new restaurant/marina office.

Based on the information provided I have the following comments:

- 1. It appears the 100-foot Buffer has not been properly expanded in areas of steep slopes and should be revised.
- 2. While the existing marina is designated as a water-dependent facility, Section 41.8 of the Comprehensive Zoning Ordinance (CZO) states that only those specific operations and structures that must occupy the Buffer in order to serve their function may be located in the Buffer. The new marina office/restaurant is restricted from this list and therefore may not be relocated in the Buffer as proposed.
- 3. Similarly, the proposed bath house should be located entirely outside of the expanded 100-foot Buffer.
- 4. My review of GIS data indicates a stream may be located on the property running through the nontidal wetland. Per Section 71.8.3 of the CZO tributary streams require a 100-foot Buffer. Additionally, the site plan should show a 25-foot buffer around the nontidal wetland.

Thank you for the opportunity to provide comments. If you have any questions, please contact me at 410-260-3475.

Sincerely,

Kate Schmidt

Natural Resource Planner

SM 164-07

St. Mary's County Government DEPARTMENT OF LAND USE AND GROWTH MANAGEMENT

Denis D. Canavan, Director Phillip J. Shire, Deputy Director



Francis Jack Russell, President Kenneth R. Dement, Commissioner Lawrence D. Jarboc, Commissioner Thomas A. Mattingly, Sr., Commissioner Daniel H. Raley, Commissioner

STAFF REVIEW/REFERRAL

June 4, 2008

CONTROL NO:

07-132-005 Cape St. Mary's Marina

TAX MAP:

15

BLOCK:

7

PARCEL:

16 (Lots 31-34 Sec 5 & Lot 22 Bk 3)

APPLICANT:

Burkhardt/Mehaffey

REVISION SUBMISSION DATE: May12, 2008

The above-referenced project satisfactorily addresses the TEC comments for the referenced meeting and is ready for signature approval.

YES

NO



COMMENTS:

- 1. Please note that Project 08-131-004 for covering and expansion of the boat house structure in Cat Creek is being concurrently reviewed and may impact parking calculations, rest room facilities, and access issues on this site.
- 2. Critical Area Commission staff comments of 4/13/08 (attached) states that "the new marina office/restaurant is restricted from this list [of water-dependent facilities] and therefore may not be relocated in the Buffer as proposed." Please coordinate with CAC and Environmental Planning Staff to resolve this issue prior to Planning Commission review.
- Please note that Department of Recreation, Parks & Community Services comments of 4/13/08 (attached) state that the relocation of the parking area for public use should be clearly marked and that a new formalized lease agreement and exhibit must be established.
- 4. Per LUGM TEC comments of 4/12/08, please add bearings & distances to all boundary lines, including the shoreline.
- 5. Per Environmental Review comments of 4/16/08, please revise the width of the boardwalk along the bulkhead to be 3 feet because any greater width may require a variance.
- 6. Please provide sketches of all proposed structures showing three dimensions.
- 7. The size and intensity of use the proposed office and restaurant appears to greatly increase from the TEC submittal. In the future, please mention such increases in size and intensity in the response letter or revision block.
- 8. Since a restaurant/office structure is not allowed in the Critical Area Buffer under the current Comprehensive Zoning Ordinance per Section 41.8.2.(2), the structure is nonconforming to the regulations. Per Section 52.3.2 no nonconforming structure shall be moved unless required by law, or unless the movement (relocation) will result in the elimination of the nonconformity. There are provisions for expanding or enlarging a nonconforming use/structure per Section 52.3.3, however, please consult with the Zoning Administrator, Yvonne Chaillet, of this office, and provide evidence that this structure is eligible for relocation, expansion, or enlargement.
- 9. Update the square footage of the proposed buildings, the FAR, and the parking calculations to reflect the proposed expanded structure.
- 10. Considering the several bar areas proposed in the structure closest to the water, it appears that Tavern use (#77) is the primary use, and that the restaurant use has been greatly

PAGE 1 OF 2

07-132-005 Cape St. Mary's Marina June 2, 2008 Page 2 of 2

minimized. Combined with the increase in the proposed structure, a tavern use would change the existing nonconforming status that may otherwise allow the relocation of the use in the Critical Area Buffer. Please provide the size of the existing restaurant/office building and percentage of food versus alcohol sales to document the current use on the property. Then calculate the proposed bar versus restaurant use of the proposed replacement structure to determine if the new structure is a change of use or simply a relocation of the nonconforming use.

11. A dance hall (Recreational Facility, minor indoors #67) is shown on the plan. Use #67 is not permitted in the CM. Revise the use of the structure and delete "Dance Hall." Will it

be used as a dining area?

12. Please update General Note #5 to include all existing and proposed uses on the property including Marine Terminal Use (#103), and indicate areas on this site on which this use is primarily located.

13. Please show the location of storm water management on the plan.

14. Please provide a traffic analysis as part of the APF study and delete General Note #18 on the plan as this remodel surely would increase the traffic flow to the site.

15. Please provide the information per general requirements of Use #101, to ensure that the bath house and other facilities can accommodate the required number of lavatory and bathing facilities as well as location of laundry for live aboard vessels. In complying with Section 51.3.101.(4)-(6) the slips required for the total number of slips, including those slips on the opposite side of Cat Creek.

16. The Critical Area Buffer shall be planted with a "C" buffer yard using native vegetation.

A planting plan will be required a the major site plan review stage

APPLICANT ACTION: Address the above comments and submit the revised plan. Then obtain and verify approvals from all TEC agencies and submit final site plan for approval.

REVIEWED / REFERRED BY:

Christine Allred, Plans Reviewer

Attachments: CAC

CAC staff comments of 4/13/08

RP&CS comments of 4/13/08

CC:

Gregory Burkhardt

45118 St. Cuthbert Farm Rd Hollywood, MD 20636

Mehaffey & Associates, PC

\\GC\DMS\HTLTR\PZLTR\PROD\PZ2007\P0007730.DOC

You can check the status of your project and read future staff comments by going to the County website at www.co.saint-marys.md.us. Go to "EGOV" and click on "Plan Review Comments." Follow the directions for entering your Project Number. Your Project Number can be found in the "Case File Number" section above.

a. To determine the status of your project, click on "Revlews" and select the review type your project is currently undergoing (e.g. minor subdivision).

b. To read staff reports, click on "Project Text" or "Project Documents" and select the report you want to read.

St. Mary's County Government DEPARTMENT OF LAND USE AND GROWTH MANAGEMENT Denis D. Canavan, Director

Phillip J. Shire, Deputy Director



Board of County Commissioners Francis Jack Russell, President Kenneth R. Dement, Commissioner Lawrence D. Jarboe. Commissioner Thomas A. Mattingly, Sr., Commissioner Daniel H. Raley, Commissioner

MEMORANDUM:

TO.

The Applicant

FROM:

Environmental Review/Dept, of Land Use and Growth Management

SUBJ:

TEC Items on Agenda

DATE:

April 16, 2007

Pursuant to the provisions of the St. Mary's County Development Ordinances, the following comments are offered for consideration in review of:

Reviewed In accordance with Zoning Ordinance

Case File Number: MAJOR SITE PLAN #07-13200005

Name of Project: CAPE ST MARY'S MARINA

I have reviewed the plat for compliance with Critical Area (CA) requirements per Critical Area Criteria currently in effect and for compliance with the Resource Protection provisions of CZO 02-01 and have noted that following must be addressed in order for the proposal to be considered for approval.

General comments.

- Add the CA Boundary to the vicinity map. a)
- b) It appears that the parking space Immediately adjacent to the travel lift slip is Impractical due both to the activities associated with launching and pulling boats and to the location of the proposed relocated gas pump. Relocate that space. See also comment 2)a)i). Provision of planting bed will
- Comments regarding minimum Critical Area Criteria; Chapter 41 St. Mary's County Critical Area 2) Maryland Ordinance for the Chesapeake Bay Critical Area Program.
 - Regarding §41.5.3.i.(3) Impervious surface trading: a)
 - Per paragraph (a), for a site that exceeds the impervious surface limit, when one trades IS the areas where IS is removed should be planted in natural forest vegetation. Staff recognizes the purpose of moving the restaurant office structure is revise the parking and ramp access to improve site circulation and parking. Therefore staff would recommend that an area equivalent to the footprint of the restaurant be established elsewhere in the Buffer as a means to capture and infiltrate runoff before it enters the tidal waters.

Staff recommendation is to relocate the restaurant parking east of the existing hoat ramp by:

- (1) Provide a 3 foot boardwalk at the bulkhead to accommodate access to the shoreline or transient boats for fuel purchases, and for restaurant and office customers.
- (2) Provide a minimum 15 foot wide x 200 foot long planting bed planted to the end of the bulkhead and a minimum 5 foot wide x 160 foot long planting bed along the gravel area behind the restaurant/office (approximately 3700 s.f.)
- (3) Provide controlled access to the beach and board walk via several board or gravel walks cross the planting beds to eliminate damage to plantings from foot traffic.
- (4) All planting beds in the CA Buffer to be planted with native salt tolerant trees, shrubs and perennials

Placement of the relocated fuel pump as shown on the plan and removal of the parking space per comment 1.b. to accommodate unimpeded use of the travel lift access to the fuel pump

- II) Per paragraph (b) à maximum of 1000 square feet IS can be traded however because the proposed area for placement of the new restaurant is over existing IS this provision shall be be walved.
- b) The expanded Critical Area Buffer is not properly delineated on the Existing Conditions plan. Due to highly erodible soils (EwE2), steep slopes, hydric soils (Tm), and the areas of tidal and nontidal wetlands, the entire site is encumbered by the expanded CA Buffer. Properly show the expanded CA Buffer on the plans, change CA note 2 to say "expanded CA Buffer" and update the impervious surface figures in the applicable CA notes accordingly.
- 3) Comments regarding Resource Protection requirements of Chapter 71 (CZO 02-01) requirements for future development/disturbance on these lots if approved:
 - a) The proposed office restaurant structure and shop building will have to be brought into compliance with the Chapter 76 Floodplain regulations. The restaurant/ office building and all mechanical and electrical equipment must be elevated to the Flood protection elevation of 7' NAVD 1988. All areas below the flood protection elevation shall be flood vented. Floodproofing may be possible for the shop building. Applicant should work with staff to make this determination. Consult with the building code official to determine if and how the buildings will be made handicapped accessible.
 - b) No other environmental concerns have been identified for this site.

Sm164-07 Page 1 of 2

Schmidt, Katherine

From: Sue Veith [Sue.Veith@co.saint-marys.md.us]

Sent: Monday, July 21, 2008 11:47 AM

To: Schmidt, Katherine

Subject: Re: Cape St. Mary's Marina

I met with the owners consultants on Friday and told them they must reduce the building size to the same footprint area as the current restaurant/office because an expansion triggers not only a variance but nonconforming use issues as well. They agreed to do this. It is my understanding that the boatel is to be removed and an replacement shop constructed but I note that Christine who reviewed the plan questioned whether this was true and also questioned the size of the replacement shop building. If the shop is a partial replacement of the boatel the expanded footprint would need a variance, if a replacement the shop would need to have the same footprint as the boatel. I am bringing this to the owner's consultants' attention.

The walkway adjacent to the new planting beds is at the edge of the bulkhead because it is used for tying up boats launched from the public ramp and for fueling. Non slip holders using the public ramp, transients, and restaurant patrons will be tying up and accessing boats from the walkway, hauling supplies and materials to an from boats using dock carts and I am told that there is need for the walk for wheel chair access for one of the marina patrons who currently has to be carried to get to his boat. Because of the use of the walk I believe a 6 foot wide walk can be justified as water dependent and should be approved to be located in the Buffer.

In other areas to the left (facing the water) of the public ramp, another walk is proposed and I discussed its purpose with the consultants. I was told the walk is desired as a continuation of the existing walk serving the leftmost piers and slips but that is mostly requested to prevent vehicles from pulling up to the edge of the bulkhead. Patrons don't hit the existing walk when parking but they do hit the top of the bulkhead and use it as a wheel stop when they park facing forward (and particularly when they backing in) where there is no walk or structure. With the removal of the restaurant, the owner has said fears damage to the bulkhead from hitting the bulkhead top and also from the weight of the cars parking so close to the bulkhead and he fears for the safety of patrons if they don't stop or the bulkhead fails while they are parking and finally he has a concern about the pollutants coming off the vehicles with their front ends hanging past the bulkhead, so he requested the walk at the face of the bulk head to provide for site circulation between the docks and vehicles for carts and pedestrians and to prevent damage to the bulkhead and creek. I suggested a planting bed could do the same thing—the consultant said he'd look at it but the owner believes the walk solves the parking issue and meets the need for dock cart access from the parking spaces to the docks and they don't think that there is enough room for the walk, a planting bed, parking spaces and drive aisle on the left end of the Marina.

I have asked that they provide added area of planting within the parking lot (beds were originally sized to offset the footprint of the restaurant only) to also offset the footprints of all walkways and all other replacement impervious surfaces and have directed that they must fully plant the shoreline at the southernmost end of the property (the natural area beyond the restaurant and parking lot adjacent to where the plan calls for removal of a large area of existing gravel parking which is also to be vegetated) to establish a minimum 100 foot wide riparian buffer along the Patuxent and to meet the C Buffer yard planting requirement for marinas per the ordinance.

Sue Veith AICP
Environmental Planner
St. Mary's County Land Use and Growth Management
23150 Leonard Hall Drive
P.O. Box 653
Leonardtown, MD 20650
ph. 301-475-4200 ext. 1547
fax 301-475-4635
sue veith@co.saint-marys.md.us

>>> On 7/21/2008 at 9:14 AM, in message <5C01472C9A95304E891798DA3B9CB408422F6B@tawesmail2.langroup.dnr.md>, "Schmidt, Katherine" <KSchmidt@dnr.state.md.us> wrote:

Good Morning Sue:

Marshall just came in my office with your question about Cape St. Mary's and I know I'm woefully overdue in getting back to you myself.

Anyway, here is a summary of our discussion this morning. To start, I think this is a situation where the

applicant requires a variance, if it does not meet the impervious surface trading policy. I realize that nearly the entire site is paved or gravel, however the structures are being relocated and expanded within the Buffer. To me, the expansion of the marina building and boatel increases the nonconformity of the site, triggering the variance.

However, I do think the staff direction in attempting to improve the water quality situation is great mitigation for the proposal. We would definitely encourage a site design that adds more vegetation and other infiltration or stormwater treatment opportunities. As far as the proposed walkway goes, we wonder if this must be located at the edge of the bulkhead or could it be located a few feet back from the edge of the bulkhead? Remember with the 2008 changes, the walkway will contribute to lot coverage.

I know this is not completely helpful, but it is consistent with what we tell other jurisdictions in terms of when a variance is required for properties like this.

Thanks,

Kate Schmidt

Regional Program Chief


Critical Area Commission for the

Chesapeake and Atlantic Coastal Bays

1804 West Street, Suite 100

Annapolis, MD 21401

410-260-3475



1. The entire site is within the Maryland Critical area. All development activities proposed within this area is subject to Critical Area regulations and will not be permitted until all appropriate local, state, and federal agencies have conducted a thorough environmental review and have approved the development plan.

The 100 foot Critical Area Buffer must remain in natural vegetation and may not be disturbed except as provided under Section 41.7 of the St. Mary.s County Comprehensive Zoning Ordinance, Buffer Management Overlay Designation.

3. No development is permitted in wetlands without approval from the appropriate local, State and Federal agencies.

4. All forest shown hereon shall remain undisturbed except as permitted under the provisions of the St. Mary.s County Comprehensive Zoning Ordinance. Any and all afforested or reforested areas created under the provisions of the St. Mary.s County Comprehensive Zoning Ordinance and designated on the plat shall be preserved from

5. Existing impervious surface within 100 foot Critical Area Buffer is 86,383 square feet.

9. Locations of natural heritage areas, habitats of threatened or endangered species, and habitats of significant plants or wildlife are identified on the plat in accordance with Section 41.7 of the St. Mary.s County Comprehensive Zoning Ordinance, Buffer Management Overlay Designations.

6. Area of slopes 15% or greater is 367,909 square feet. 7. Existing trees or forested area is 852383 square feet.

10. Proposed area of vegetation clearing is 5,230 square feet

12. Proposed area of additional impervious surface is O square feet

Chapter 4. Guide to BMP Selection and Location in Maryland

"A" Soils May

Require Pond

Liner

B" Soils May

Require

Testing

OK

"A" Soils

OK

 $f \ge 0.52$ Inch/Hr

Made Soil.

Unless adequate water balance and anti-clogging device installed

Require Liner | Or Aquifer

DRAINAGE

AREA

10 Min²

5 Max³

5 Max

5 Max

10 Max

10 Max 3

2 Max 3

2 Max 3

5 Max³

5 Max

5 Max

TABLE

lf Hotspot

 \mathbf{Or}

Aquifer

Below WT

If Hotspot

4 Feet1

2 Feet

1 Four foot separation distance is maintained to the seasonally high water table (2 feet on Lower

4.11

Made Soil 2 Feet

4 Feet¹

SLOPE

RESTRICT.

None

Than 15%

Slopes

None

4% Max

Cross-slope

11. Proposed area of soil disturbance is 118,198 square feet.

Table 4.4 BMP Selection - Physical Feasibility

BMP LIST.

P-1 Micropool ED

P.2 Wet Pend

P 3 Wet ED Pond

P-5 Pocket Pond

W 2 ED Worland

W 3 Pend Wotlend

W-4 Pocket Wetland

I-1 Infiltration Trench

1-2 Infiltration Basin

F-1 Surface Sand Filter

F 2 Underground SF

F-3 Perimeter SF

F-4 Organic Filter

F-5 Pocket SF

F-6 Bioretention

O 1 Dry Swale

O 2 Wet Swale

Notes: OK = not restricted, WT = water table

Drainage area can be larger in some instances

W 1 Shallow Wetland

8. Existing impervious surface is 144,827 square feet.

Critical Area Notes

CODE

Critical Area Summary

	Slopes Greater Than 15%	Vegetation	Pavement/ Gravel	Boat Repair Shop	Restaruant
Existing	342,110 SF	969,739 SF	135,607 SF	3,988 SF	3,692 SF
Proposed		See Planting Table	1,482 SF	3,984 SF	3,672 SF
Removed		5,288 SF	38,299 SF		
Disturbed	8,369 SF	18,416 SF			

CONCEPT PLAN

Cape St. Mary's Marina

for: Greg's Burkhardt Mechanicsville, Maryland

Sixth Election District

Abbreviations

Finished Floor

Storm drain


Edge of Pave


ST. MARY'S COUNTY


METROPOLITAN COMMISSION

Corrugated Metal Pipe

St. Mary's Co., Maryland








TYPICAL SECTION

Parking Table

	PAVEMENT	
/	ST. MARY'S COUNTY	
	SOIL CONSERVATION DISTRICT	
2 manieca I.		
	DISTRICT MANAGER DATE	
**************************************	DISTRICT PRIMALE	



Revertible slope and

Drainage Easement

Soll Group Line

____X-__X-__

•——RD———RD——•

Centerline

Wood Line

Stabilize Construction Entrance

Brilly Andre To Sandar Brilly Sandar Sandar Sandar Sand

X 360,60


Location Map Scale: 1"= 600"

INDEX OF DRAWINGS

JARYLAND, LICENSE NO. 17625, EXPIRATION DATE 12/11/09

Sheet #	Name		
ł	Cover Sheet		
2	Existing Condition & Environmental Features		
3	Proposed Condition		

DATE



Vicinity Map

GENERAL NOTES Property Address: 27290 Holly Lane

LUGM File Number: 07-132-005

4. Property Data:
Tax map 15, Block 07, Parcel 16 (Lots 31 to 34 Sect. 5 & Lot 22 block 3)
Total site area: 40.34 acres +/- or 1,757,210 Sq. Ft.
Sixth Election District
Deed Reference: EWA Liber 1710 Folio 172
Zoning District: CM (LDA Overlay)

Use 101 - Marina "High" use intensity Use 61 - Office "Low" use intensity Use 71 - Restaurant "Low" use intensity Use 100 - Dock, ramp and/or railway, public "Low" use intensity

6. Building Information:

Marina Office/Restaurant = 3,672 square feet
Boat Repair Shop = 3,984 square feet
Bath House = 525 square feet

Yard setbacks - front 25 ft. (Minor Collector or Less)

Buffer yards: Aight-of-Way (No buffer yard required)
Commercial ("B" buffer yard required)
Residential ("C" buffer yard required)

Parking requirements:
Parking shown on plan are a representation on gravel area and will not have marked out stalls.

a. maximum - 4 per 1,000 sf gross floor area or 0.004 spaces/sf (Schedule 64.3.1 use #61) maximum - 10 per 1,000 sf gross floor area or 0.010 space/sf (Schedule 64.3.1 use #71)

b. maximum - 400 sf * 0.004 spaces per sf = 2 spaces maximum - 3,272 sf * 0.010 spaces per sf = 33 spaces Maximum spaces = 35 spaces

Maximum spaces = 35 spaces

c. number of spaces provided: 25 spaces
d. Vehicle with Boat Trailer spaces provided: 24 spaces (15'x 40' spaces)

14 of the 24 spaces are for the public boat ramp use.
e. Slip Holder's parking required: 118 slips @ 1 per 5 slips 118/5 = 24 spaces (Schedule 64.3.1 use #101)
f. Slip Holder's parking provided: 35 spaces
g. Boat Repair Shop parking 1 per employee = 1 space
h. ADA spaces required: 3
i. ADA spaces provided: 3 spaces provided (1 van accessible)
h. Total car Parking required=60 spaces
Total car Parking provided=60 spaces

10. Loading Zone Data:

Loading zones required (schedule 64.3.2): 1 loading zone (per schedule 64.3.2) Group 2 Use: #61

12. The property is located in flood hazard zone "C" as indicated on the firm panel #240037C0111E dated 10-19-04.

Onsite Topography taken from Offenbacher, LS plan dated February 2003. Offsite Topography per County Topography Maps.

14. Tidal and Non-tidal wetlands are shown per Offenbacher, LS plan dated February 2003.

Stormwater management will be addressed in accordance to the 2000 Maryland Stormwater Management Design Manual. Proposed impervious surfaces are offset by the removal of existing impervious surfaces. A geo-technical engineer will d a comprehensive evaluation of all the surface areas in the design phase.

16. Site lighting will be addressed per the St. Mary's County Comprehensive Zoning Ordinance (Section 64.10.4). Lighting shall be directed down and shall not shine directly onto adjacent property.

17. The site is exempt from forest conservation, per section 75.2.2.h.1 of the St. Mary's County Zoning Ordinance.

18. The property is currently in operation and no traffic increase is expected by the proposed remodel.

Total Disturbed Area: Area to be vegetatively stabilized Earthwork: ** 0.45 acres 550 cubic yards 1,100 cubic yards

**Earthwork and Estimated Quantities
Earthwork quantities shown hereon are provided to the Owner for
Soil Conservation District approval and bonding purposes only.
The Contractor should be aware that these quantities should not be used for bidding purposes. Quantities are base on Engineering Drawings and calculations and no allowance has been made for unsuitable soils, compaction, shrinkage, haul loss, or other similar

Assumptions: No Compaction. Calculations based on 6" topsoil. Cross sections of earthwork can be made available with permission from the Owner.



Sheet 1 of 3

LUGM # 07-132-00005

Cover Sheet Cape St. Mary's Marina Located in Mechanicsville, Maryland

Tax Map 15, Blk. 7, Par. 16 St. Mary's Co., Md. 6th Election District

ST. MARY'S COUNTY ST. MARY'S COUNTY ST. MARY'S COUNTY DEPARTMENT OF DEPARTMENT OF DEPARTMENT OF ENVIRONMENTAL HEALTH PUBLIC WORKS LAND USE AND GROWTH MANAGEMENT Sanitarian Environmental Health Director DIRECTOR

Physical Feasibility

URBAN

Practical

OK

Practical

Practical

Depends

OK

Practical

(F1)

6 to 8 Ft

4 Ft.

3 to 5 Ft.

3 Ft

5 to 7ft

2 to 3 Ft

2 to 4 Ft

2 to 5 Ft

5 Ft.

3 to 5 Ft

5 Ft

2 To 3 Ft Depends

Designed By: D. Mills Date: Mar. 7, 2007 | Scale: As Shown 9/10/08 Revise per LUGM and MDE Meeting 6/11/08 Revise per HD 4/30/08

Revise per TEC Comments

REVISION

MEHAFFEY & ASSOCIATES, P.C. Civil & Environmental Engineering • Land Planning 41650 Court House Drive ~ Loker Building -Suite 100 PO Box 2450 Leonardtown, Maryland 20650

301.475.0406 Fax 301.475.2822

